

Warrick® Series 16HM Controls Installation and Operation Bulletin

This bulletin should be used by experienced personnel as a guide to the installation of series 16HM controls. Selection or installation of equipment should always be accompanied by competent technical assistance. We encourage you to contact Gems Sensors or its representative if further information is required.

Specifications

Control Design: Solid state components enclosed in clear Lexan plug-in style housing. Housing carries no NEMA rating.

Contact Design: SPDT (1 form C): one normally open (N.O.) and one normally closed (N.C.), non-powered contacts.

Contact Ratings: 10A @ 120 or 240 VAC resistive, 1/3 H.P. @120 or 240 VAC.

Contact Life: Mechanical- 5 million operations. Electrical- 100,000 operations minimum at rated load.

Supply Voltage: 24, 120, or 240 VAC models- factory

set. Plus 10%, minus 15%, 50/60 Hz.

<u>Current Consumption</u>: 120, 240, 24 VAC, Relay

energized 4.4 VA.

Secondary Circuit: 12 VDC voltage on probes, 1.5

micro-amp current.

Sensitivity: Models operate from 0-5,500,000 OHM

maximum specific resistance- factory set. **Temperature:** -40° to 150° F, ambient.

Terminals: All connections #6-32 screw type with pres-

sure clamps.

Time Delays: Standard, 0.5 seconds on rising level. Additional time delays on rising and/or falling available as option.

Listing: UL listed, Industrial Motor Control (508).


Installation

- 1. Install octal socket in appropriate enclosure using two #6 or #8 metal screws.
- Install rail mount socket on appropriate rail (DIN mount) in appropriate enclosure if applicable.
- 2. Wire control per wiring diagram, following N.E.C. and local codes
- Install control module in socket.


Maximum Probe Wire Distance

Maximum distance between control and probe is limited to the total of the resistance of the wire and resistance of the liquid. The total must not exceed the sensitivity of the control.

Dimensional Diagram



Use copper (60/70° C) wire only. Torque to 20 inch pounds.



Operation

Direct Mode- Single Level Service: When the liquid rises to the electrode on terminal 3, the control energizes, changing state of the load contacts. (*LED will be lit*) The control remains energized until the liquid level recedes below electrode on terminal 3. The control then de-energizes, (*LED will not be lit*) returning load to original state.

Sensitivity in single level service is one-half that of differential service (using a single probe). To obtain maximum sensitivity, (listed sensitivity) two probes of equal length, plus ground reference, must be used (terminals 3, 4, 5).

Inverse Mode- Single Level Service: Control energizes with power, changing state of the load contacts. *(LED will be lit)* When the liquid rises to the electrode on terminal 3, the control de-energizes, returning the load contacts to shelf state. *(LED will not be lit)* The control remains de-energized until liquid level recedes below the electrode connected to terminal 3. The control then energizes.

Direct Mode- Differential Service: When the liquid rises to the electrode on terminal 3, the control energizes, changing state of the load contacts. *(LED will be lit)* The control remains energized until the liquid level recedes below electrode on terminal 4. The

control then de-energizes, (LED will not be lit) returning the load contacts to original state.

Inverse Mode- Differential Service: Control energizes with power, (*LED will be lit*) changing state of the load contacts. When the liquid rises to the electrode on terminal 3, the control de-energizes, returning load contacts to shelf state. (*LED will not be lit*) The control remains de-energized until the liquid level recedes below the electrode on terminal 4. The control then energizes.

Optional

Time Delays: With time delay on increasing level, the liquid must be in contact with the short electrode for the full duration of the time delay before control will operate. With delay on decreasing level, the liquid must be below long electrode for the full duration of the time delay before control will operate. In single level service, terminals 3 and 4 must be jumpered together to achieve time delays on both increasing and decreasing levels or just decreasing level.

